



**NOTES:**

1. IB FASTENERS & MEMBRANE PLATES INSTALLED 6" O.C. WITH A MINIMUM OF 3 FASTENERS FOR PIPES LESS THAN 12" IN DIAMETER (12" O.C. WITH MINIMUM OF 4 FASTENERS FOR PIPES GREATER THAN 12" DIAMETER).
2. SEALANTS AND CAULKING REQUIRE PERIODIC OWNER MAINTENANCE.
3. ROOF PENETRATIONS EXCEEDING 120°F, REFER TO THE IB HOT PIPE FLASHING DETAIL.
4. CLEAN PENETRATION PRIOR TO FLASHING TO REMOVE ALL BITUMINOUS RESIDUE OR CONTAINMENTS.

<p><b>Scale:</b> NTS</p>	<p><b>Detail Name:</b> <i><b>IB Pipe Flashing</b></i></p>	<p><b>Detail Number:</b> <i><b>PS - 01</b></i></p>
<p><b>Submitted By:</b> Address: Telephone:</p>		<p><b>Project:</b> Address:</p>